



SUPPLEMENTAL BID BULLETIN

TO: ALL PROSPECTIVE BIDDERS

This Supplemental Bid Bulletin is issued to amend **Section VII: Technical Specifications** of Lot No. 2 – Procurement of 2 units Generator Set for the use of Provincial Government Facilities outside the Government Center under bid no. B20242754 with PhilGEPS Reference No. 10939916 published on June 12, 2024, viz:

FROM	TO
2 units GENERATOR SET Unit Type: Output Power: 70KW or 87.5 KVA Voltage Recovery Time: less than 5 seconds Rated Voltage: 127V/230V Rated Frequency: 60Hz System & Joining: Three phase four wire Rated Current: 220A Reference Weight: 650kg Dimensions: 2600mm x 110mm x 1450mm Cooling Method: Closed Water Cooling Noise Limit: Not Exceeding 77 decibels Starting Mode: Electric Start Number of Cylinders: 4 Starting Power Supply: DC 12V-24V	2 units GENERATOR SET Unit Type: Output Power: 70KW or 87.5 KVA (Standby Power) Voltage Recovery Time: less than 5 seconds Rated Voltage: 127V/230V Rated Frequency: 60Hz System & Joining: Three phase four wire Rated Current: 220A Reference Weight: 650kg Dimensions: 2600mm x 110mm x 1450mm Cooling Method: Closed Water Cooling Noise Limit: Not Exceeding 77 decibels Starting Mode: Electric Start Number of Cylinders: 4 Starting Power Supply: DC 12V-24V Commissioning and Testing at site Load Bank Test on site Warranty: 1 year or 1000 hrs. whichever comes first

For guidance and information of all concerned.

Issued this 26th day of June, 2024.


DENNIS DEAN T. CASTILLO, MPA
 Chairperson, Bids and Awards Committee
 Acting Provincial Administrator